

HPU-42HF03	Indoor ambient temp. sensor	001A3800127	001A3900003	R25=23K Ω \pm 2 B25/50=4200K
	Indoor coil temp. sensor	0010401922	001A3900004	R25=10K Ω \pm 1 B25/50=3700K
	Outdoor defrost sensor	0010401922	001A3900004	R25=10K Ω \pm 1 B25/50=3700K

R25=23K Ω \pm 2.5% B25/50=4200K \pm 3%		R25=23K Ω \pm 2.5% B25/50=4200K \pm 3%					
T(°C)	Rnom(K Ω)	2°C	74.67	25°C	23	48°C	8.39
-20°C	281.34	3°C	70.65	26°C	21.94	49°C	8.05
-19°C	263.56	4°C	66.88	27°C	20.94	50°C	7.73
-18°C	247.04	5°C	63.33	28°C	19.99	51°C	7.43
-17°C	231.66	6°C	60	29°C	19.09	52°C	7.14
-16°C	217.35	7°C	56.86	30°C	18.23	53°C	6.86
-15°C	204.02	8°C	53.91	31°C	17.42	54°C	6.6
-14°C	191.61	9°C	51.13	32°C	16.65	55°C	6.34
-13°C	180.04	10°C	48.51	33°C	15.92	56°C	6.1
-12°C	169.24	11°C	46.04	34°C	15.22	57°C	5.87
-11°C	159.17	12°C	43.72	35°C	14.56	58°C	5.65
-10°C	149.77	13°C	41.52	36°C	13.93	59°C	5.44
-9°C	140.99	14°C	39.45	37°C	13.34	60°C	5.24
-8°C	132.78	15°C	37.5	38°C	12.77		
-7°C	125.11	16°C	35.66	39°C	12.23		
-6°C	117.93	17°C	33.92	40°C	11.71		
-5°C	111.22	18°C	32.27	41°C	11.22		
-4°C	104.93	19°C	30.72	42°C	10.76		
-3°C	99.04	20°C	29.25	43°C	10.31		
-2°C	93.52	21°C	27.86	44°C	9.89		
-1°C	88.35	22°C	26.54	45°C	9.49		
0°C	83.5	23°C	25.3	46°C	9.1		
1°C	78.94	24°C	24.12	47°C	8.74		